

# WHS-PRO-008 Asbestos Management Procedure

## Appendix 1 - Risk Assessment Algorithm for Insitu ACM



Adapted from WHS “Asbestos Survey Guide HSG264, second edition, 2012” to meet the guidance outlined in the Safe Work Australia 2011 Code of Practice *How to Manage and Control Asbestos in the Workplace*.

**Product Type Score (A)      Examples**

1

	Unsealed AIB, or encapsulated lagging and sprays.
3	Unsealed lagging and sprays.

Scores are added together to provide an assessment of the “Potential to release asbestos fibres”.

SCORE (A+B+C)	Potential for fibre release
7 or more	High
5 to 7	Medium

3	Occupied area or air handling system

Scores are added to together to provide an assessment of risk to occupants.

RISK SCORE (A+B+C+D)	RISK RANKING
11 or more	Very High
9 to 10	